



Inch	mm
1/2	15
3/4	20
1	25

**TABLE 6-4**  
**Water Supply Fixture Units (WSFU) and Minimum Fixture Branch Pipe Sizes<sup>3</sup>**

Appliances, Appurtenances or Fixtures <sup>2</sup>	Minimum Fixture Branch Pipe Size <sup>1,4</sup>	Private	Public	Assembly <sup>6</sup>
Bathtub or Combination Bath/Shower (fill) .....	1/2"	4.0	4.0	
3/4" Bathtub Fill Valve .....	3/4"	10.0	10.0	
Bidet .....	1/2"	1.0		
Clotheswasher .....	1/2"	4.0	4.0	
Dental Unit, cuspidor .....	1/2"		1.0	
Dishwasher, domestic .....	1/2"	1.5	1.5	
Drinking Fountain or Watercooler .....	1/2"	0.5	0.5	0.75
Hose Bibb .....	1/2"	2.5	2.5	
Hose Bibb, each additional <sup>8</sup> .....	1/2"	1.0	1.0	
Lavatory .....	1/2"	1.0	1.0	1.0
Lawn Sprinkler, each head <sup>5</sup> .....		1.0	1.0	
Mobile Home, each (minimum) .....		12.0		
<b>Sinks</b>				
Bar .....	1/2"	1.0	2.0	
Clinic Faucet .....	1/2"		3.0	
Clinic Flushometer Valve .....				
with or without faucet .....	1"		8.0	
Kitchen, domestic .....	1/2"	1.5	1.5	
Laundry .....	1/2"	1.5	1.5	
Service or Mop Basin .....	1/2"	1.5	3.0	
Washup, each set of faucets .....	1/2"		2.0	
Shower, per head .....	1/2"	2.0	2.0	
Urinal, 1.0 GPF Flushometer Valve .....	3/4"	See Footnote 7		
Urinal, greater than 1.0 GPF Flushometer Valve .....	3/4"	See Footnote 7		
Urinal, flush tank .....	1/2"	2.0	2.0	3.0
Washfountain, circular spray .....	3/4"		4.0	
Water Closet, 1.6 GPF Gravity Tank .....	1/2"	2.5	2.5	3.5
Water Closet, 1.6 GPF Flushometer Tank .....	1/2"	2.5	2.5	3.5
Water Closet, 1.6 GPF Flushometer Valve .....	1"	See Footnote 7		
Water Closet, greater than 1.6 GPF Gravity Tank .....	1/2"	3.0	5.5	7.0
Water Closet, greater than 1.6 GPF Flushometer Valve .....	1"	See Footnote 7		

**Notes:**

1. Size of the cold branch pipe, or both the hot and cold branch pipes.
2. Appliances, Appurtenances or Fixtures not included in this Table may be sized by reference to fixtures having a similar flow rate and frequency of use.
3. The listed fixture unit values represent their load on their cold water service. The separate cold water and hot water fixture unit value for fixtures having both hot and cold water connections may each be taken as three-quarter ( 3/4) of the listed total value of the fixture.
4. The listed minimum supply branch pipe sizes for individual fixtures are the nominal (I.D.) pipe size.
5. For fixtures or supply connections likely to impose continuous flow demands, determine the required flow in gallons per minute (GPM) and add it separately to the demand (in GPM) for the distribution system or portions thereof.
6. Assembly [Public Use (See Table 4-1)].
7. When sizing flushometer systems see Section 610.10.
8. Reduced fixture unit loading for additional hose bibbs as used is to be used only when sizing total building demand and for pipe sizing when more than one hose bibb is supplied by a segment of water distributing pipe. The fixture branch to each hose bibb shall be sized on the basis of 2.5 fixture units.




Table 6-5

**TABLE 6-5**  
 Fixture Unit Table for Determining Water Pipe and Meter Sizes

**Pressure Range – 30 to 45 psi (207 to 310 kPa)\*\***

Meter and Street Service, Inches	Building Supply and Branches, Inches	Maximum Allowable Length in Feet (meters)														
		40 (12)	60 (18)	80 (24)	100 (30)	150 (46)	200 (61)	250 (76)	300 (91)	400 (122)	500 (152)	600 (183)	700 (213)	800 (244)	900 (274)	1000 (305)
3/4	1/2***	6	5	4	3	2	1	1	1	0	0	0	0	0	0	0
3/4	3/4	16	16	14	12	9	6	5	5	4	4	3	2	2	2	1
3/4	1	29	25	23	21	17	15	13	12	10	8	6	6	6	6	6
1	1	36	31	27	25	20	17	15	13	12	10	8	6	6	6	6
3/4	1-1/4	36	33	31	28	24	23	21	19	17	16	13	12	12	11	11
1	1-1/4	54	47	42	38	32	28	25	23	19	17	14	12	12	11	11
1-1/2	1-1/4	78	68	57	48	38	32	28	25	21	18	15	12	12	11	11
1	1-1/2	85	84	79	65	56	48	43	38	32	28	26	22	21	20	20
1-1/2	1-1/2	150	124	105	91	70	57	49	45	36	31	26	23	21	20	20
2	1-1/2	151	129	129	110	80	64	53	46	38	32	27	23	21	20	20
1	2	85	85	85	85	85	85	82	80	66	61	57	52	49	46	43
1-1/2	2	220	205	190	176	155	138	127	120	104	85	70	61	57	54	51
2	2	370	327	292	265	217	185	164	147	124	96	70	61	57	54	51
2	2-1/2	445	418	390	370	330	300	280	265	240	220	198	175	158	143	133

Inch	mm
1/2	15
3/4	20
1	25
1-1/4	32
1-1/2	40
2	50
2-1/2	65

**Pressure Range – 46 to 60 psi (317 to 414 kPa)\*\***

3/4	1/2***	7	7	6	5	4	3	2	2	1	1	1	0	0	0	0
3/4	3/4	20	20	19	17	14	11	9	8	6	5	4	4	3	3	3
3/4	1	39	39	36	33	28	23	21	19	17	14	12	10	9	8	8
1	1	39	39	39	36	30	25	23	20	18	15	12	10	9	8	8
3/4	1-1/4	39	39	39	39	39	39	34	32	27	25	22	19	19	17	16
1	1-1/4	78	78	76	67	52	44	39	36	30	27	24	20	19	17	16
1-1/2	1-1/4	78	78	78	78	66	52	44	39	33	29	24	20	19	17	16
1	1-1/2	85	85	85	85	85	85	80	67	55	49	41	37	34	32	30
1-1/2	1-1/2	151	151	151	151	128	105	90	78	62	52	42	38	35	32	30
2	1-1/2	151	151	151	151	150	117	98	84	67	55	42	38	35	32	30
1	2	85	85	85	85	85	85	85	85	85	85	85	85	85	83	80
1-1/2	2	370	370	340	318	272	240	220	198	170	150	135	123	110	102	94
2	2	370	370	370	370	368	318	280	250	205	165	142	123	110	102	94
2	2-1/2	654	640	610	580	535	500	470	440	400	365	335	315	285	267	250

**Pressure Range – Over 60 psi (414 kPa)\*\***

3/4	1/2***	7	7	7	6	5	4	3	3	2	1	1	1	1	1	0
3/4	3/4	20	20	20	20	17	13	11	10	8	7	6	6	5	4	4
3/4	1	39	39	39	39	35	30	27	24	21	17	14	13	12	12	11
1	1	39	39	39	39	38	32	29	26	22	18	14	13	12	12	11
3/4	1-1/4	39	39	39	39	39	39	39	39	34	28	26	25	23	22	21
1	1-1/4	78	78	78	78	74	62	53	47	39	31	26	25	23	22	21
1-1/2	1-1/4	78	78	78	78	78	74	65	54	43	34	26	25	23	22	21
1	1-1/2	85	85	85	85	85	85	85	85	81	64	51	48	46	43	40
1-1/2	1-1/2	151	151	151	151	151	151	130	113	88	73	51	51	46	43	40
2	1-1/2	151	151	151	151	151	151	142	122	98	82	64	51	46	43	40
1	2	85	85	85	85	85	85	85	85	85	85	85	85	85	85	85
1-1/2	2	370	370	370	370	360	335	305	282	244	212	187	172	153	141	129
2	2	370	370	370	370	370	370	370	340	288	245	204	172	153	141	129
2	2-1/2	654	654	654	654	654	650	610	570	510	460	430	404	380	356	329

\*\*Available static pressure after head loss.

\*\*\*Building supply, three-quarter (3/4) inch (20 mm) nominal size minimum.